

ARCO Facility No. 5695, 44239 Margarita Road, Temecula, California

Staff Contact: Sean McClain

The San Diego Water Board intends to issue a no further action letter for cleanup of an unauthorized release of petroleum fuel wastes from a leaking underground storage tank (UST) system at the ARCO Station in Temecula, California. This public notice fulfills the Regional Board's obligation to inform the public of completed corrective action as required by California Code of Regulations (CCR), Title 23, Division 3, Chapter 16, Article 11, section 2728. Fifteen groundwater monitoring wells were installed and used to delineate the extent of the groundwater plume. A total of 1,768,370 gallons of groundwater was extracted, treated, and re-injected from 2002 to 2007 to remediate the site. The current site conditions do not pose a threat to human health or the environment, and the unauthorized release case can be closed. The case files are available for public review by submitting a file review request to the San Diego Water Board office, or on-line from the [Geotracker database](#). Provided no significant issues arise during the public notification period, the San Diego Water Board will issue a no further action letter after December 10, 2010.